



EDUCATION DEPARTMENT
GOVERNMENT OF SIKKIM
GANGTOK

Memo No. - S12/AE/GTK/EDN.

Date - 04-06-2024

BUILDING SAFETY CERTIFICATE

This is to Certify that a physical inspection of **Government Senior Secondary School Sang**, having **CBSE Affiliation No. 1820021** located at **Sang in East Sikkim** on **3rd of June 2024** was conducted by the field engineer of Education Department (Gangtok), where it was found that the above mentioned school has four R.C.C. framed structures with the following details as mentioned below:-

1. **Old school building** - 2 storeyed R.C.C building with 17 classrooms.
The built in plinth area is 5,570.00 ft².
2. **Annex school building** - 2 storeyed R.C.C building with 6 classrooms.
The built in plinth area is 2,040.00 ft².
3. **RMSA building** - 2 storeyed R.C.C building with 4 classrooms.
The built in plinth area is 750.00 ft².
4. **Auditorium** – Single storyed R.C.C. auditorium hall with G.C.I sheet.
The built in plinth area is 3,600.00 ft².

The visual inspection revealed that the columns, beams and slabs have no cracks or shear stress of any kind, the partition were also found to be free from cracks, till date the school buildings has no significant damages and defects. Hence, the structures can be certified to be fairly safe.

This Certificate is valid for a period of one year from the date of issue.

Assistant Engineer
Assistant Engineer (Gangtok),
Education Department,
Government of Sikkim.

Superintending Engineer (N/E),
Superintending Engineer,
Education Department,
Government of Sikkim.
Govt. of Sikkim