



EDUCATION DEPARTMENT
GOVERNMENT OF SIKKIM
GANGTOK

Memo No. *548/22(EI)/Edu*

Date- *28/09/2022*

BUILDING SAFETY CERTIFICATE

This is to Certify that the **Government Senior Secondary School, having CBSE Affiliation No. 1820012** located at **Sang in East Sikkim**, an inspection was conducted on 27th of September 2022 by the field engineer of Education Department (East-I), where it was found that the above mentioned school have four R.C.C framed structures with following details mention below:-

1. Old school building:- R.C.C building comprises of two-storeyed with 17 rooms for classes, the built in plinth area is 3,570 ft².
2. Annex school building:- R.C.C building comprises of two-storeyed having 6 rooms for classes, the built in plinth area is 2,040 ft².
3. RMSA building:- R.C.C building comprises of two-storeyed having 4 rooms for classes, the built in plinth area is 750 ft².
4. Auditorium:- R.C.C auditorium hall with G.C.I sheet, the built in plinth area is 3,600 ft².

The visual inspection revealed that the columns, beams and slabs had no cracks or shear stress of any kind, the partitions were also found to be free from cracks. Till date the school buildings have no significant damages and defects. Hence, the structure can be certified to be fairly safe.

This Certificate is valid for a period of one year from the date of issue.

[Signature]
Assistant Engineer, East-I
Education Department
Govt. of Sikkim

[Signature]
Divisional Engineer (E)
Education Department
Govt. of Sikkim

Copy to : 1. Superintending Engineer (East)

2. Office copy

